



Certificate of Compliance

Trade Name: Bradflo "Premiumflex" R0.6 Polyester insulated flexible duct

Product Code Prefix: ABCD_F

Manufactured by: Bradflo Pty Ltd
20 Garland Avenue
Albury NSW 2640

Description: Silver/Black polyester core with a mechanical spring wire helix.
35mm thick R0.6 polyester insulation.
Fire rated polyester outer sleeve.

Test Description	Test Result	Testing Authority	Test No.	Date
AS 1530.3	Spread of flame 0, Smoke dev 1, Heat transmitted 0, Ignitability 0	AWTA	7-495462-CN	17/10/00
UL 181 Burning	Pass	AWTA	7-495186-CN	05/10/00
UL 181 Mould growth	Pass	AWTA	7-497351-CN	09/01/01
UL 181 Temperature	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Puncture	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Static load	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Impact	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Pressure	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Collapse	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Tension	Pass	AWTA	7-495807-CN	31/10/00

The flexible duct shown on this certificate has achieved the above results and therefore complies with the Building Code of Australia (BCA) when tested in accordance with AS 4254-2002 and its amendments.

Signed on behalf of Bradflo Pty Ltd

Raymond Judd
General Manager

Date: 08/08/2008



10 Year
Warranty

Head Office
20 Garland Avenue Albury NSW 2640
PH: (02) 6058 6900 **FAX:** (02) 6058 6928
ABN 75 079 923 256