



Certificate of Compliance

Trade Name: Bradflo "Superflex" R0.6 Polyester insulated flexible duct

Product Code Prefix: APDFR_F

Manufactured by: Bradflo Pty Ltd
20 Garland Avenue
Albury NSW 2640

Description: Black metalised polyester core with a mechanical spring wire helix.
35 mm thick R0.6 Polyester insulation.
Polyester/ metalised polyester laminated outer sleeve reinforced with polyester scrim.

Test Description	Test Result	Testing Authority	Test No.	Date
AS 1530.3	Spread of flame 0, Smoke dev 2, Heat transmitted 0, Ignitability 0	AWTA	7-485076-CN	28/06/99
UL 181 Burning	Pass	AWTA	7-485086-CN	28/06/99
UL 181 Mould growth	Pass	AWTA	7-470486-CN	07/08/97
UL 181 Temperature	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Puncture	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Static load	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Impact	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Pressure	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Collapse	Pass	AWTA	7-485314-CN	06/07/99
UL 181 Tension	Pass	AWTA	7-485314-CN	06/07/99

The flexible duct shown on this certificate has achieved the above results and therefore complies with the Building Code of Australia (BCA) when tested in accordance with AS 4254-2002 and its ammendments.

Signed on behalf of Bradflo Pty Ltd

Raymond Judd
General Manager

Date: 08/08/2008



Head Office
20 Garland Avenue Albury NSW 2640
PH: (02) 6058 6900 FAX: (02) 6058 6928
ABN 75 079 923 256

10 Year
Warranty