



Certificate of Compliance

Trade Name: Bradflo "Superflex" R1.5 Polyester insulated flexible duct

Product Code Prefix: APDFR_F

Manufactured by: Bradflo Pty Ltd
20 Garland Avenue
Albury NSW 2640

Description: Silver/Black metalised polyester core with a mechanical spring wire helix.
65mm thick R1.5 polyester insulation.
Fire rated polyester/metalized polyester laminated outer sleeve.

Test Description	Test Result	Testing Authority	Test No.	Date
AS 1530.3	Spread of flame 0, Smoke dev 1, Heat transmitted 0, Ignitability 0	AWTA	7-495462-CN	17/10/00
UL 181 Burning	Pass	AWTA	7-563865-CN	12/12/08
UL 181 Mould growth	Pass	AWTA	7-497351-CN	09/01/01
UL 181 Temperature	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Puncture	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Static load	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Impact	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Pressure	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Collapse	Pass	AWTA	7-495807-CN	31/10/00
UL 181 Tension	Pass	AWTA	7-495807-CN	31/10/00

The flexible duct shown on this certificate has achieved the above results and therefore complies with the Building Code of Australia (BCA) when tested in accordance with AS 4254-2002 and its ammendments.

Signed on behalf of Bradflo Pty Ltd

Raymond Judd
General Manager

Date: 18/12/2008



10 Year
Warranty

Head Office
20 Garland Avenue Albury NSW 2640
PH: (02) 6058 6900 **FAX:** (02) 6058 6928
ABN 75 079 923 256